

No. Fail: JBPM/IP/RNP:700-7/2/25-141 (2)
(BAHARU)

SIJIL PEPASANGAN KESELAMATAN KEBAKARAN

APPROVAL CERTIFICATE

Jabatan Bomba dan Penyelamat Malaysia
dengan ini memperakukan
Fire and Rescue Department of Malaysia
hereby certify

WALL SYSTEM
(LIGHTWEIGHT CONCRETE WALL PANEL)
'UAC' Model : AIRCRETE PANEL
2 JAM (LOAD BEARING)

Berdasarkan Piawaian
Complying with

BS 476:PART 21:1987

Syarikat Berdaftar
Registered company

UAC SOLIDPANEL SDN BHD (218336-V)
LEVEL 10, Menara UAC, 12 Jalan PJU 7/5,
Mutiara Damansara,
47800 Petaling Jaya,
Selangor DE.

Tempoh sah perakuan: **06/03/2024 hingga 05/03/2026**


(KAMARULZAMAN MALIK ABDULLAH)

Pengarah
Bahagian Perancangan dan Penyelidikan,
b.p. Ketua Pengarah
Jabatan Bomba dan Penyelamat Malaysia.

Tarikh: 25 Mac 2024

** Peringatan:

Sila patuhi sepenuhnya surat-surat dan had kegunaan seperti dalam Lampiran A1



CERTIFIED TO ISO 9001:2015
CERT. NO QMS 02101



CERTIFIED TO ISO 37001:2016
CERT. NO ABMS 00216

Jenis Bahan Binaan	:	LIGHTWEIGHT CONCRETE WALL PANEL 2 JAM (LOAD BEARING)
Jenama & Spesifikasi	:	'UAC' / Model : AIRCRETE PANEL 3000mm (h) x 600mm (w) x 125mm (t)
Nama & Alamat Pengeluar	:	UAC SOLIDPANEL SDN BHD
Tahap Rintangan Api	:	Loadbearing Capacity: 120 min Integrity: 120 min Insulation: 120 min
No. Laporan ujian/Tarikh	:	SIRIM 2024FE0007 (15/01/2024)
Skim Persijilan Barangan	:	-----
Had Kegunaan	:	HENDAKLAH MEMATUHI SPESIFIKASI UJIAN, UBBL 1984 SERTA SYARAT-SYARAT TAMBAHAN SEPERTI DI LAMPIRAN A2 & A3.

UAC

Tempoh sah perakuan: **06/03/2024 hingga 05/03/2026**

